

## Adriana Milan

---

**From:** Adam Lanning  
**Sent:** Tuesday, January 5, 2021 11:08 AM  
**To:** Adriana Milan  
**Subject:** FW: Well #8 - Repairs  
**Attachments:** Well #8 Additional Equipment-Wiring Repair Product Submittal - Engel Electric Co..pdf  
  
**Importance:** High

---

**From:** Scott McGinn <scottm@engelectric.com>  
**Sent:** Friday, November 20, 2020 2:06 PM  
**To:** Jay Mulholland <jmulholland@rmu.net>  
**Cc:** Adam Lanning <alanning@rmu.net>  
**Subject:** Well #8 - Repairs  
**Importance:** High

Jay,

See attached product data sheet. The following is what we have covered in our additional quote:

- Additional time on site troubleshooting system prior to startup. Gary had an extra day working with you people as you may recall
- Repair vault light/power (pump switch and LED Light)
- Furnish and install service entrance surge protection and overcurrent protection for surge device
- Remove old breaker and furnish/install new Square D
- Pull new wire from VFD to well pump splice box (3) 350 XHHW-2 with Ground XHHW-2
- Install remote VFD key pad control (exterior of MCC cabinet)
- Install in-line output filter (wired on line side of VFD)

**Total projected costs: \$21,941.00**

If you would like itemized costs or need a formal proposal; please advise. I am on vacation next week, but will be checking emails from time to time.

I would also like to share the submittal (attached) with Mike Nailor and his people to review to ensure we are all in agreement with this plan.

Thank you,

*Scott J. McGinn*

Vice President  
Office: 815-625-5949 Ext. 107 - Cell: 815-716-3644



1514 W. Fourth Street,  
Sterling, IL 61081  
Phone: 815-625-5949  
Fax: 815-625-5987

5280 11<sup>th</sup> Street,  
Rockford, IL 61109  
Phone: 815-625-5949  
Fax: 815-625-5987

**"An Equal Opportunity Employer"**  
visit our website at [www.engelectric.com](http://www.engelectric.com)

The information contained in and transferred with this electronic message is intended only for the recipient(s) designated above, it is protected by law and it may contain information which is privileged and confidential. If you are not the intended recipient, you are hereby notified that any review, dissemination, distribution, copying or use of this message is unauthorized and strictly prohibited. If you have received this message in error, please notify Engel Electric Co. immediately.